**Accessibility Survey** 



# City of Downey Cavel Street - Brookshire Avenue to Boyne Street

Brookshire Avenue to Boyne Street Downey, CA 90242

Date of Inspection 8/30/2017

Prepared By

**Disability Access Consultants** 

(800) 743-7067

**Sidewalks - Exterior : Sidewalks** 

#### North Side @ 33.928200986619, -118.137083351612

Sidewalks : No Sidewalk

#### **Finding**

No sidewalk exists at the location.

**On-Site Finding** Not Found

#### Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

**Costing Info (Estimated)** 

Unassigned



Code Reference ADA 206

#### **Progress**

**Record Number** 483385 Resolution None **Progress** Not\_Started **Priority** Seven **Actual Date Projected Date** 06/30/2037 Contractor **Actual Cost** \$0.00 Comments No Comments Assignment None **New Value** 0 **Designated Staff** 

#### **Cavel Street - Brookshire Avenue to Boyne Street**

**Sidewalks - Exterior : Sidewalks** 

#### South Side @ 33.928120867507, -118.137112855911

Sidewalks : No Sidewalk

#### **Finding**

No sidewalk exists at the location.

**On-Site Finding** Not Found

#### Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

**Costing Info (Estimated)** 

Unassigned



Code Reference ADA 206

#### **Progress**

**Record Number** 483386 Resolution None **Progress** Not\_Started **Priority** Seven **Actual Date Projected Date** 06/30/2037 Contractor **Actual Cost** \$0.00 Comments No Comments Assignment None **New Value** 0 **Designated Staff** 



Cavel Street - Brookshire Avenue to Boyne Street

## Brookshire Avenue to Boyne Street Downey, CA 90242

Date of Inspection 8/30/2017

\*Estimated Facility Total: \$0

\*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By


**Disability Access Consultants** 

(800) 743-7067

**Prepared Using** 



### **Accessibility Survey**



## City of Downey Cavel Street - Brookshire Avenue To End

Brookshire Avenue To End Downey, CA 90242

Date of Inspection 2/1/2017

Prepared By

**Disability Access Consultants** 

(800) 743-7067

#### **Cavel Street - Brookshire Avenue To End**

**Sidewalks - Exterior : Sidewalks** 

#### **North Side**

#### Sidewalk East Of End @ 33.929246979220, -118.139390051365

Sidewalks : Missing Sidewalk

#### Finding

Section of sidewalk is missing and consists of dirt, grass or gravel.

**On-Site Finding** 719.00 feet

#### Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

**Costing Info (Estimated)** 

\$1,260



**Code Reference** ADA 206, 302,CA 11B-302,CA 11B-206

#### **Progress**

<b>Record Number</b>	349124	Resolution	None
Progress	Not_Started	Priority	Seven
<b>Actual Date</b>		<b>Projected Date</b>	06/30/2037
<b>Actual Cost</b>	\$0.00	Contractor	

**Comments** No Comments

**Assignment** None **New Value** 0

**Designated Staff** 

**Sidewalks - Exterior : Sidewalks** 

#### **South Side**

#### Sidewalk West Of Brookshire Avenue @ 33.928301135403, -118.137566149235

Sidewalks : Missing Sidewalk

#### **Finding**

Section of sidewalk is missing and consists of dirt, grass or gravel.

**On-Site Finding** 663.00 feet

#### Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

**Costing Info (Estimated)** 

\$1,260



**Code Reference** ADA 206, 302,CA 11B-302,CA 11B-206

#### **Progress**

Assignment

<b>Record Number</b>	349125	Resolution	None
Progress	Not_Started	Priority	Seven
<b>Actual Date</b>		<b>Projected Date</b>	06/30/2037
<b>Actual Cost</b>	\$0.00	Contractor	
Comments	No Comments		

Designated Staff

None

New Value 0

#### Sidewalks - Exterior : Sidewalks , Hazards & Gratings

#### **South Side**

#### Tree West Of Brookshire Avenue @ 33.928249948261, -118.137434720993

Sidewalks , Hazards & Gratings : Overhead Obstruction Height

#### **Finding**

Overhead obstruction height is not compliant.

On-Site Finding 70.00 inches

#### Recommendation

Provide a compliant vertical clearance height.

Recommendation At least 80.00 inches

**Costing Info (Estimated)** 


Unassigned



**Code Reference** ADA 206, 307.4,CA 11B-307.4

#### **Progress**

<b>Record Number</b>	349126	Resolution	None
Progress	Not_Started	Priority	Seven
<b>Actual Date</b>		<b>Projected Date</b>	06/30/2032
<b>Actual Cost</b>	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			



Cavel Street - Brookshire Avenue To End

### Brookshire Avenue To End Downey, CA 90242

Date of Inspection 2/1/2017

\*Estimated Facility Total: \$2,520

\*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By

**Disability Access Consultants** 

(800) 743-7067

**Prepared Using** 

