

## Accessibility Survey

---



### City of Downey Parkcliff Street - Barlin Avenue To Blodgett Avenue

Barlin Avenue To Blodgett Avenue  
Downey, CA 90242

Date of Inspection  
11/28/2016

Prepared By

**Disability Access Consultants**

(800) 743-7067

## Parkcliff Street - Barlin Avenue To Blodgett Avenue

### Sidewalks - Exterior : Sidewalks , Hazards & Gratings

---

#### South Side

#### Bush West Of Blodgett Avenue @ 33.905252683713, -118.148190379143

Sidewalks , Hazards & Gratings : Sidewalk Width at Obstruction

#### Finding

Sidewalk width at the obstruction is not compliant.

**On-Site Finding** 24.00 inches

#### Recommendation

Sidewalk width at the obstruction shall have the recommended value.

Recommendation At least 48.00 inches

#### Costing Info (Estimated)

\$1,260



**Code Reference** ADA 206, 302, 403.5.1, CA 11B-403.5

#### Progress

---

<b>Record Number</b>	310788	<b>Resolution</b>	None
<b>Progress</b>	Not_Started	<b>Priority</b>	Four
<b>Actual Date</b>		<b>Projected Date</b>	06/30/2023
<b>Actual Cost</b>	\$0.00	<b>Contractor</b>	
<b>Comments</b>	No Comments	<b>New Value</b>	0
<b>Assignment</b>	None		
<b>Designated Staff</b>			

## Parkcliff Street - Barlin Avenue To Blodgett Avenue

### Sidewalks - Exterior : Sidewalks , Hazards & Gratings

---

#### South Side

#### Tree West Of Blodgett Avenue @ 33.904956608005, -118.147495687008

Sidewalks , Hazards & Gratings : Overhead Obstruction Height

#### Finding

Overhead obstruction height is not compliant.

**On-Site Finding** 70.00 inches

#### Recommendation

Provide a compliant vertical clearance height.

Recommendation At least 80.00 inches

#### Costing Info (Estimated)

Unassigned



**Code Reference** ADA 206, 307.4,CA 11B-307.4

#### Progress

---

<b>Record Number</b>	310789	<b>Resolution</b>	None
<b>Progress</b>	Not_Started	<b>Priority</b>	Four
<b>Actual Date</b>		<b>Projected Date</b>	06/30/2023
<b>Actual Cost</b>	\$0.00	<b>Contractor</b>	
<b>Comments</b>	No Comments		
<b>Assignment</b>	None	<b>New Value</b>	0
<b>Designated Staff</b>			

**Parkcliff Street - Barlin Avenue To Blodgett Avenue**



**Parkcliff Street - Barlin Avenue To Blodgett Avenue**

**Barlin Avenue To Blodgett Avenue  
Downey, CA 90242**

Date of Inspection  
11/28/2016

**\*Estimated Facility Total: \$1,260**

\*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By

**Disability Access Consultants**

(800) 743-7067

Prepared Using

