

Accessibility Survey



City of Downey Cord Avenue - Cecilia Street to Fostoria Street

Cecilia Street to Fostoria Street
Downey, CA 90242

Date of Inspection
6/13/2017

Prepared By
Disability Access Consultants
(800) 743-7067

Cord Avenue - Cecilia Street to Fostoria Street

Sidewalks - Exterior : Sidewalks

East Side @ 33.935582749178, -118.114016354084

Sidewalks : No Sidewalk

Finding

No sidewalk exists at the location.

On-Site Finding Not Found

Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

Costing Info (Estimated)

Unassigned



Code Reference ADA 206

Progress

Record Number	446717	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Cecilia Street to Fostoria Street

Sidewalks - Exterior : Sidewalks

West Side @ 33.935647283925, -118.114171922207

Sidewalks : No Sidewalk

Finding

No sidewalk exists at the location.

On-Site Finding Not Found

Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

Costing Info (Estimated)

Unassigned



Code Reference ADA 206

Progress

Record Number	446716	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Cecilia Street to Fostoria Street



Cord Avenue - Cecilia Street to Fostoria Street

**Cecilia Street to Fostoria Street
Downey, CA 90242**

Date of Inspection
6/13/2017

***Estimated Facility Total: \$0**

*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By

Disability Access Consultants

(800) 743-7067

Prepared Using



Accessibility Survey



City of Downey Cord Avenue - Cedartree Road to Brookpark Road

Cedartree Road to Brookpark Road
Downey, CA 90242

Date of Inspection
6/14/2017

Prepared By
Disability Access Consultants
(800) 743-7067

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

East Side

Sidewalk South of Cedartree Road @ 33.953647230402, -118.101595044136

Sidewalks : Missing Sidewalk

Finding

Section of sidewalk is missing and consists of dirt, grass or gravel.

On-Site Finding 146.00 feet

Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

Costing Info (Estimated)

\$1,260



Code Reference ADA 206, 302,CA 11B-302,CA 11B-206

Progress

Record Number	448417	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

East Side @ 33.953647230402, -118.101595044136

Sidewalks : 60X60 Turn Area

Finding

There is no 60X60 turn area at every 200 feet.

On-Site Finding Not Found

Recommendation

Provide a 60X60 turn every 200 feet on the sidewalk.

Recommendation See Recommendation

Costing Info (Estimated)

\$2,400



Code Reference ADA 206, 302

Progress

Record Number	448906	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

West Side

Sidewalk North of Cedartree Road @ 33.952618224242, -118.102327287197

Sidewalks : Missing Sidewalk

Finding

Section of sidewalk is missing and consists of dirt, grass or gravel.

On-Site Finding 42.00 feet

Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

Costing Info (Estimated)

\$1,260



Code Reference ADA 206, 302,CA 11B-302,CA 11B-206

Progress

Record Number	448411	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

West Side

Sidewalk North of Cedartree Road @ 33.952880761050, -118.102194517851

Sidewalks : Missing Sidewalk

Finding

Section of sidewalk is missing and consists of dirt, grass or gravel.

On-Site Finding 40.00 feet

Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

Costing Info (Estimated)

\$1,260



Code Reference ADA 206, 302,CA 11B-302,CA 11B-206

Progress

Record Number	448413	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

West Side

Sidewalk North of Cedartree Road @ 33.953247866246, -118.102016150951

Sidewalks : Missing Sidewalk

Finding

Section of sidewalk is missing and consists of dirt, grass or gravel.

On-Site Finding 41.00 feet

Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

Costing Info (Estimated)

\$1,260



Code Reference ADA 206, 302,CA 11B-302,CA 11B-206

Progress

Record Number	448412	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

West Side

Sidewalk North of Cedartree Road @ 33.953508176243, -118.101888746023

Sidewalks : Missing Sidewalk

Finding

Section of sidewalk is missing and consists of dirt, grass or gravel.

On-Site Finding 100.00 feet

Recommendation

Provide a compliant sidewalk for the missing section.

Recommendation See Recommendation

Costing Info (Estimated)

\$1,260



Code Reference ADA 206, 302,CA 11B-302,CA 11B-206

Progress

Record Number	448414	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks , Surface

West Side

Sidewalk North of Cedartree Road @ 33.953904743, -118.102136850357

Sidewalks , Surface : Cross Slope

Finding

Sidewalk cross slope is not compliant.

On-Site Finding 3.10 percent for 98.00 feet

Recommendation

Repave the sidewalk surface with the recommended cross slope.

Recommendation Up to 2.08 percent

Costing Info (Estimated)

Repave surface \$1,092



Code Reference ADA 206, 302,CA 11B-403.3

Progress

Record Number	448415	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road

Sidewalks - Exterior : Sidewalks

West Side @ 33.951548044636, -118.102838248014

Sidewalks : 60X60 Turn Area

Finding

There is no 60X60 turn area at every 200 feet.

On-Site Finding Not Found

Recommendation

Provide a 60X60 turn every 200 feet on the sidewalk.

Recommendation See Recommendation

Costing Info (Estimated)

\$2,400



Code Reference ADA 206, 302

Progress

Record Number	448905	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Cedartree Road to Brookpark Road



Cord Avenue - Cedartree Road to Brookpark Road

**Cedartree Road to Brookpark Road
Downey, CA 90242**

Date of Inspection
6/14/2017

***Estimated Facility Total: \$12,192**

*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By

Disability Access Consultants

(800) 743-7067

Prepared Using



Accessibility Survey



City of Downey Cord Avenue - Pellet Street to Cul-De-Sac

Pellet Street to Cul-De-Sac
Downey, CA 90242

Date of Inspection
6/13/2017

Prepared By
Disability Access Consultants
(800) 743-7067

Cord Avenue - Pellet Street to Cul-De-Sac

Sidewalks - Exterior : Sidewalks

East Side @ 33.93286118606, -118.11553259850

Sidewalks : No Sidewalk

Finding

No sidewalk exists at the location.

On-Site Finding Not Found

Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

Costing Info (Estimated)

Unassigned



Code Reference ADA 206

Progress

Record Number	446714	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Pellet Street to Cul-De-Sac

Sidewalks - Exterior : Sidewalks

West Side @ 33.932927880822, -118.115684688091

Sidewalks : No Sidewalk

Finding

No sidewalk exists at the location.

On-Site Finding Not Found

Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

Costing Info (Estimated)

Unassigned



Code Reference ADA 206

Progress

Record Number	446715	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Pellet Street to Cul-De-Sac



Cord Avenue - Pellet Street to Cul-De-Sac

**Pellet Street to Cul-De-Sac
Downey, CA 90242**

Date of Inspection
6/13/2017

***Estimated Facility Total: \$0**

*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By

Disability Access Consultants

(800) 743-7067

Prepared Using



Accessibility Survey



City of Downey Cord Avenue - Via Amorita to Florence Avenue

Via Amorita to Florence Avenue
Downey, CA 90242

Date of Inspection
8/6/2017

Prepared By
Disability Access Consultants
(800) 743-7067

Cord Avenue - Via Amorita to Florence Avenue

Sidewalks - Exterior : Sidewalks

East Side @ 33.941073591029, -118.110221028328

Sidewalks : No Sidewalk

Finding

No sidewalk exists at the location.

On-Site Finding Not Found

Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

Costing Info (Estimated)

Unassigned



Code Reference ADA 206

Progress

Record Number	476954	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments	New Value	0
Assignment	None		
Designated Staff			

Cord Avenue - Via Amorita to Florence Avenue

Sidewalks - Exterior : Sidewalks

West Side @ 33.941149247572, -118.110371232033

Sidewalks : No Sidewalk

Finding

No sidewalk exists at the location.

On-Site Finding Not Found

Recommendation

No action necessary until a sidewalk is provided.

Recommendation See Recommendation

Costing Info (Estimated)

Unassigned



Code Reference ADA 206

Progress

Record Number	476953	Resolution	None
Progress	Not_Started	Priority	Six
Actual Date		Projected Date	06/30/2027
Actual Cost	\$0.00	Contractor	
Comments	No Comments		
Assignment	None	New Value	0
Designated Staff			

Cord Avenue - Via Amorita to Florence Avenue



Cord Avenue - Via Amorita to Florence Avenue

Via Amorita to Florence Avenue
Downey, CA 90242

Date of Inspection
8/6/2017

***Estimated Facility Total: \$0**

*Estimated facility total is for estimating purposes only and does not represent total construction, repair totals or design fees.

Prepared By

Disability Access Consultants

(800) 743-7067

Prepared Using

